

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WARREN COUNTY       )  
WATER DISTRICT FOR A DEVIATION FROM    )  
THE REQUIREMENTS OF 807 KAR 5:066,     )  
SECTION 5(4), AND SECTION 10(3),        )  
REGARDING WATER STORAGE AND SERVICE    )  
LINE INSPECTION                            )  
CASE NO. 10328

O R D E R

By letter received July 21, 1988, Warren County Water District ("Warren") requested a deviation from 807 KAR 5:066, Section 5(4), and Section 10(3), which require a water utility to provide water storage to insure one day's supply of its average daily water usage and to inspect customers' service lines.


On November 29, 1988, Joe Liles, manager of Warren requested that this case be dismissed. The Commission will treat this request as a motion and finds that it should be granted. The Commission also finds that Warren should comply with 807 KAR 5:066, Section 5(4), and Section 10(3).


IT IS THEREFORE ORDERED that:

1. This case be and it hereby is dismissed without prejudice.
2. Warren shall comply with 807 KAR 5:066, Section 5(4), and Section 10(3).

Done at Frankfort, Kentucky, this 20th day of December, 1988.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

\_\_\_\_\_  
Executive Director